



DESTRATIFICATION FAN DETAIL

SCALE: NONE

NOTES:

1. CONTRACTOR SHALL INSTALL METAL CLAD CABLE TO MANUFACTURER SUPPLIED JUNCTION BOX AND RECEPTACLE.
2. DRILL EACH OF THE FOUR RIGHT ANGLE CORNER TABS AND SECURE TO THE STRUCTURE ABOVE WITH MECHANICS WIRE.