



## DESTRATIFICATION FAN DETAIL

SCALE: NONE

NOTES:

1. INSTALL FAN AS CLOSE AS POSSIBLE TO CEILING.  
(TYP 0'-6" TO 2'-0")
2. OPTIONAL HANGING METHODS INCLUDE: BEAM CLAMP/BRIDLE RING, CHAIN LINK/CARABINER, THREADED ROD/LOCK NUTS, ETC...
3. CONTRACTOR TO PROVIDE POWER FEED IN CONDUIT. THE ELECTRICAL CONNECTION CAN BE MADE IN A J-BOX (HARD WIRED) OR PLUG CONNECTION (J-BOX/RECEPTACLE).